



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN from UL #13257153.18 and #13257153.12

[TESTLAB]

[ISSUE DATE] 9-FEB-2021

[MANUFAC] H E Williams Inc

[LUMCAT] 4CSDI-L12-835U-L12-835D-xxx-DIM1-UNV-OM-CSU-OW-CSD-WM

[MORE]

[LUMINAIRE] White formed aluminum housing, medium distrib anodized aluminum reflector trim w/clear cover glass up,
[MORE] wide distrib anodized alum open reflector trim down

[LAMP] Two white LEDs (one up/one down)

[BALLAST] (2) ERP PHB30W-0700-42 Drivers

[OTHER]

[OTHER] This test was performed using the calibrated photodetector met

[MORE] hod of absolute photometry.

[CONVERT] Photometric web converted from original test data

[CONVERT] Luminaire test position and photometric web converted from original test data

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2034
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	72
Total Luminaire Watts	28.2
Ballast Factor	1.00
CIE Type	General Diffuse
Spacing Criterion (0-180)	N.A.
Spacing Criterion (90-270)	N.A.
Spacing Criterion (Diagonal)	N.A.
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.21 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.00 ft

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES****LUMINANCE DATA (cd/sq.m)**

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	42240	42467	44254
55	18570	23431	19409
65	807	3749	807
75	387	387	387
85	231	231	231

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>	<u>112.5</u>	<u>135.0</u>	<u>157.5</u>	<u>180.0</u>
0.0	1179.027	1179.027	1179.027	1179.027	1179.027	1179.027	1179.027	1179.027	1179.027
2.5	1178.220	1172.571	1169.343	1168.536	1166.922	1168.536	1169.343	1172.571	1178.220
5.0	1151.589	1146.747	1143.519	1142.712	1141.905	1142.712	1143.519	1146.747	1151.589
7.5	1111.239	1106.397	1103.976	1103.976	1103.169	1103.976	1103.976	1106.397	1111.239
10.0	1059.591	1054.749	1053.942	1053.135	1052.328	1053.135	1053.942	1054.749	1059.591
12.5	994.224	991.803	990.996	990.189	989.382	990.189	990.996	991.803	994.224
15.0	917.559	916.752	917.559	915.945	914.331	915.945	917.559	916.752	917.559
17.5	834.438	833.631	835.245	834.438	832.017	834.438	835.245	833.631	834.438
20.0	746.314	746.717	747.524	747.282	744.377	747.282	747.524	746.717	746.314
22.5	657.301	658.351	658.512	658.593	655.042	658.593	658.512	658.351	657.301
25.0	572.324	574.180	575.633	573.858	569.177	573.858	575.633	574.180	572.324
27.5	483.393	488.719	493.238	488.074	481.456	488.074	493.238	488.719	483.393
30.0	397.205	406.082	414.717	405.114	397.447	405.114	414.717	406.082	397.205
32.5	321.428	329.014	341.603	329.014	322.558	329.014	341.603	329.014	321.428
35.0	259.531	263.485	276.962	265.019	261.791	265.019	276.962	263.485	259.531
37.5	211.111	211.757	222.167	214.662	215.308	214.662	222.167	211.757	211.111
40.0	173.505	172.133	177.863	176.087	179.396	176.087	177.863	172.133	173.505
42.5	144.211	141.709	144.937	146.551	150.425	146.551	144.937	141.709	144.211
45.0	120.162	117.903	120.808	122.906	125.892	122.906	120.808	117.903	120.162
47.5	98.535	97.728	101.682	102.489	103.135	102.489	101.682	97.728	98.535
50.0	78.360	79.812	85.058	84.009	81.910	84.009	85.058	79.812	78.360
52.5	59.718	63.349	69.402	66.900	62.381	66.900	69.402	63.349	59.718
55.0	42.852	47.855	54.069	50.760	44.788	50.760	54.069	47.855	42.852
57.5	28.487	33.571	39.139	35.589	29.455	35.589	39.139	33.571	28.487
60.0	16.866	21.143	25.501	22.273	16.705	22.273	25.501	21.143	16.866
62.5	7.263	10.894	14.203	10.975	6.617	10.975	14.203	10.894	7.263
65.0	1.372	3.228	6.375	2.824	1.372	2.824	6.375	3.228	1.372
67.5	1.049	0.968	2.179	0.968	1.049	0.968	2.179	0.968	1.049
70.0	0.726	0.726	0.807	0.726	0.807	0.726	0.807	0.726	0.726
72.5	0.565	0.565	0.565	0.565	0.565	0.565	0.565	0.565	0.565
75.0	0.403	0.403	0.403	0.403	0.403	0.403	0.403	0.403	0.403
77.5	0.323	0.323	0.323	0.323	0.323	0.323	0.323	0.323	0.323
80.0	0.242	0.242	0.242	0.242	0.242	0.242	0.242	0.242	0.242
82.5	0.161	0.161	0.161	0.161	0.161	0.161	0.161	0.161	0.161
85.0	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081
87.5	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081
90.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92.5	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100
95.0	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100
97.5	0.199	0.199	0.199	0.199	0.199	0.199	0.199	0.199	0.199
100.0	0.199	0.199	0.199	0.199	0.299	0.199	0.199	0.199	0.199
102.5	0.299	0.299	0.299	0.299	0.398	0.299	0.299	0.299	0.299
105.0	0.498	0.498	0.498	0.498	0.498	0.498	0.498	0.498	0.498
107.5	0.597	0.597	0.597	0.597	0.697	0.597	0.597	0.597	0.597
110.0	0.896	0.796	1.095	0.896	0.896	0.896	1.095	0.796	0.896
112.5	1.194	1.095	3.682	1.194	1.294	1.194	3.682	1.095	1.194
115.0	1.592	4.975	11.642	5.373	1.692	5.373	11.642	4.975	1.592
117.5	11.144	19.701	23.681	20.000	10.348	20.000	23.681	19.701	11.144
120.0	29.950	37.014	37.213	38.407	30.149	38.407	37.213	37.014	29.950
122.5	49.153	53.233	51.740	55.720	51.044	55.720	51.740	53.233	49.153
125.0	68.854	69.750	66.964	73.232	71.740	73.232	66.964	69.750	68.854
127.5	90.147	86.963	82.784	91.341	93.829	91.341	82.784	86.963	90.147
130.0	111.938	105.868	99.600	110.744	116.813	110.744	99.600	105.868	111.938
132.5	134.126	126.863	118.803	132.236	140.594	132.236	118.803	126.863	134.126

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES****CANDELA TABULATION - (Cont.)**

135.0	157.509	150.444	141.887	156.016	165.170	156.016	141.887	150.444	157.509
137.5	183.478	178.006	171.837	183.777	191.836	183.777	171.837	178.006	183.478
140.0	214.821	212.134	211.836	217.408	222.880	217.408	211.836	212.134	214.821
142.5	253.228	254.919	263.476	258.999	260.193	258.999	263.476	254.919	253.228
145.0	300.888	308.550	324.967	310.938	306.560	310.938	324.967	308.550	300.888
147.5	362.280	376.409	395.115	377.006	366.558	377.006	395.115	376.409	362.280
150.0	441.084	459.491	473.322	458.098	443.074	458.098	473.322	459.491	441.084
152.5	536.504	552.225	557.897	549.539	534.614	549.539	557.897	552.225	536.504
155.0	638.094	647.646	649.636	645.059	633.915	645.059	649.636	647.646	638.094
157.5	735.206	742.867	745.255	740.877	731.027	740.877	745.255	742.867	735.206
160.0	831.223	839.084	843.263	838.288	829.532	838.288	843.263	839.084	831.223
162.5	930.126	937.489	943.260	936.793	930.226	936.793	943.260	937.489	930.126
165.0	1028.830	1033.805	1040.770	1033.805	1027.835	1033.805	1040.770	1033.805	1028.830
167.5	1122.360	1125.345	1129.325	1124.350	1121.365	1124.350	1129.325	1125.345	1122.360
170.0	1206.935	1207.930	1206.935	1206.935	1205.940	1206.935	1206.935	1207.930	1206.935
172.5	1276.585	1276.585	1274.595	1274.595	1275.590	1274.595	1274.595	1276.585	1276.585
175.0	1330.315	1331.310	1329.320	1329.320	1330.315	1329.320	1329.320	1331.310	1330.315
177.5	1368.125	1368.125	1365.140	1366.135	1367.130	1366.135	1365.140	1368.125	1368.125
180.0	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	360.05	N.A.	17.70
0-30	621.11	N.A.	30.50
0-40	791.54	N.A.	38.90
0-60	931.02	N.A.	45.80
0-80	937.96	N.A.	46.10
0-90	938.08	N.A.	46.10
10-90	831.68	N.A.	40.90
20-40	431.49	N.A.	21.20
20-50	526.53	N.A.	25.90
40-70	145.95	N.A.	7.20
60-80	6.94	N.A.	0.30
70-80	0.47	N.A.	0.00
80-90	0.12	N.A.	0.00
90-110	0.66	N.A.	0.00
90-120	11.49	N.A.	0.60
90-130	74.28	N.A.	3.70
90-150	392.69	N.A.	19.30
90-180	1095.83	N.A.	53.90
110-180	1095.17	N.A.	53.80
0-180	2033.91	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	106.40
10-20	253.65
20-30	261.06
30-40	170.42
40-50	95.05
50-60	44.44
60-70	6.47
70-80	0.47
80-90	0.12
90-100	0.14
100-110	0.52
110-120	10.83
120-130	62.79
130-140	119.48
140-150	198.92
150-160	293.61
160-170	286.51
170-180	123.03

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	106	106	106	106	97	97	97	97	81	81	81	66	66	66	53	53	53	46
1	99	95	92	89	91	88	85	83	74	72	71	61	60	59	50	49	48	43
2	92	86	81	77	85	80	75	72	68	65	62	57	55	53	46	45	44	40
3	85	78	72	67	79	72	67	63	62	58	55	52	50	48	43	42	41	37
4	80	71	64	59	73	66	60	56	57	53	49	48	46	43	41	39	37	34
5	74	64	58	53	69	60	54	50	52	48	45	45	42	39	38	36	34	31
6	69	59	52	47	64	55	49	45	48	44	41	42	39	36	36	34	32	29
7	65	54	48	43	60	51	45	41	45	40	37	39	36	33	34	31	30	27
8	61	50	44	39	57	47	42	37	42	37	34	37	33	31	32	29	28	25
9	57	47	40	36	53	44	38	34	39	35	32	34	31	29	30	28	26	24
10	54	44	37	33	50	41	36	32	37	32	29	32	29	27	28	26	24	22

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20


Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	12.1	12.8	13.1	13.8	15.1	12.5	13.1	13.5	14.2	15.5
	3H	11.9	12.5	12.9	13.5	14.9	12.3	12.9	13.3	13.9	15.3
	4H	11.8	12.4	12.8	13.4	14.7	12.2	12.7	13.2	13.8	15.1
	6H	11.7	12.2	12.7	13.2	14.6	12.1	12.6	13.1	13.6	15.0
	8H	11.6	12.1	12.7	13.2	14.5	12.0	12.5	13.1	13.5	14.9
	12H	11.6	12.0	12.6	13.1	14.5	11.9	12.4	13.0	13.4	14.8
4H	2H	11.9	12.4	12.9	13.5	14.8	12.2	12.8	13.3	13.8	15.2
	3H	11.7	12.1	12.7	13.2	14.6	12.0	12.5	13.1	13.6	14.9
	4H	11.6	12.0	12.6	13.0	14.4	11.9	12.4	13.0	13.4	14.8
	6H	11.4	11.8	12.5	12.9	14.3	11.8	12.2	12.9	13.2	14.6
	8H	11.4	11.7	12.5	12.8	14.2	11.8	12.1	12.8	13.1	14.6
	12H	11.3	11.6	12.4	12.7	14.1	11.7	12.0	12.8	13.1	14.5
8H	4H	11.4	11.7	12.5	12.8	14.2	11.8	12.1	12.8	13.1	14.6
	6H	11.3	11.6	12.4	12.6	14.1	11.6	11.9	12.7	13.0	14.4
	8H	11.2	11.5	12.3	12.5	14.0	11.6	11.8	12.7	12.9	14.3
	12H	11.2	11.4	12.2	12.4	13.9	11.5	11.7	12.6	12.8	14.3
12H	4H	11.3	11.6	12.4	12.7	14.1	11.7	12.0	12.8	13.1	14.5
	6H	11.2	11.4	12.3	12.5	14.0	11.6	11.8	12.7	12.9	14.3
	8H	11.2	11.4	12.2	12.4	13.9	11.5	11.7	12.6	12.8	14.3

Maximum UGR = 15.5

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-OW-CSD-WM_.IES

POLAR GRAPH



Maximum Candela = 1379 Located At Horizontal Angle = 0, Vertical Angle = 180

1 - Vertical Plane Through Horizontal Angles (90 - 270)

2 - Horizontal Cone Through Vertical Angle (180) (Through Max. Cd.)