



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN from UL #13257153.18 and #13257153.21

[TESTLAB]

[ISSUE DATE] 12-15-2020

[MANUFAC] H E Williams Inc

[LUMCAT] 4CSDI-L12-835U-L12-835D-xxx-DIM1-UNV-OM-CSU-ON-CSD-WM

[MORE]

[LUMINAIRE] White formed aluminum housing, medium distrib anodized aluminum reflector trim w/clear cover glass up,
[MORE] narrow distrib anodized alum open reflector trim down

[LAMP] Two white LEDs (one up/one down)

[BALLAST] (2) ERP PHB30W-0700-42 Drivers

[OTHER]

[OTHER] This test was performed using the calibrated photodetector met

[MORE] hod of absolute photometry.

[CONVERT] Photometric web converted from original test data

[CONVERT] Luminaire test position and photometric web converted from original test data

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2012
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	71
Total Luminaire Watts	28.2
Ballast Factor	1.00
CIE Type	General Diffuse
Spacing Criterion (0-180)	N.A.
Spacing Criterion (90-270)	N.A.
Spacing Criterion (Diagonal)	N.A.
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.21 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.00 ft

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_.IES****LUMINANCE DATA (cd/sq.m)**

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	46012	42268	47856
55	23221	23956	24026
65	759	4983	807
75	387	387	387
85	231	231	231

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>	<u>112.5</u>	<u>135.0</u>	<u>157.5</u>	<u>180.0</u>
0.0	1157.238	1157.238	1157.238	1157.238	1157.238	1157.238	1157.238	1157.238	1157.238
2.5	1148.361	1148.361	1146.747	1145.940	1146.747	1145.940	1146.747	1148.361	1148.361
5.0	1116.081	1116.081	1115.274	1114.467	1115.274	1114.467	1115.274	1116.081	1116.081
7.5	1069.275	1070.082	1068.468	1067.661	1067.661	1067.661	1068.468	1070.082	1069.275
10.0	1010.364	1011.978	1011.171	1008.750	1007.943	1008.750	1011.171	1011.978	1010.364
12.5	939.348	942.576	944.190	940.155	936.120	940.155	944.190	942.576	939.348
15.0	861.069	865.104	869.946	863.490	858.648	863.490	869.946	865.104	861.069
17.5	779.804	785.292	789.730	783.839	777.625	783.839	789.730	785.292	779.804
20.0	697.894	704.592	707.578	702.736	695.473	702.736	707.578	704.592	697.894
22.5	616.951	623.165	624.941	620.744	612.674	620.744	624.941	623.165	616.951
25.0	536.494	543.514	544.806	540.125	530.925	540.125	544.806	543.514	536.494
27.5	453.615	463.702	467.656	460.636	449.983	460.636	467.656	463.702	453.615
30.0	375.820	387.602	396.640	385.827	375.174	385.827	396.640	387.602	375.820
32.5	309.646	318.926	331.596	318.846	311.260	318.846	331.596	318.926	309.646
35.0	257.272	261.549	273.573	263.324	260.257	263.324	273.573	261.549	257.272
37.5	216.115	215.711	222.732	218.616	220.150	218.616	222.732	215.711	216.115
40.0	182.301	178.912	179.557	182.624	187.305	182.624	179.557	178.912	182.301
42.5	154.218	149.295	145.825	153.411	159.705	153.411	145.825	149.295	154.218
45.0	130.895	125.246	120.243	129.443	136.141	129.443	120.243	125.246	130.895
47.5	110.236	104.668	100.149	108.784	114.594	108.784	100.149	104.668	110.236
50.0	90.787	86.591	83.524	90.303	93.854	90.303	83.524	86.591	90.787
52.5	71.581	70.612	68.998	73.679	74.002	73.679	68.998	70.612	71.581
55.0	53.585	55.764	55.279	58.427	55.441	58.427	55.279	55.764	53.585
57.5	37.364	41.722	42.125	43.820	38.575	43.820	42.125	41.722	37.364
60.0	22.273	28.245	29.698	29.455	22.031	29.455	29.698	28.245	22.273
62.5	8.473	14.526	18.238	14.687	7.182	14.687	18.238	14.526	8.473
65.0	1.291	3.631	8.473	3.874	1.372	3.874	8.473	3.631	1.291
67.5	0.968	0.888	2.582	0.968	1.049	0.968	2.582	0.888	0.968
70.0	0.726	0.646	0.888	0.726	0.726	0.726	0.888	0.646	0.726
72.5	0.565	0.484	0.484	0.484	0.565	0.484	0.484	0.484	0.565
75.0	0.403	0.403	0.403	0.403	0.403	0.403	0.403	0.403	0.403
77.5	0.323	0.242	0.242	0.242	0.323	0.242	0.242	0.242	0.323
80.0	0.161	0.161	0.161	0.161	0.242	0.161	0.161	0.161	0.161
82.5	0.161	0.161	0.161	0.161	0.161	0.161	0.161	0.161	0.161
85.0	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081
87.5	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081	0.081
90.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92.5	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100
95.0	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100
97.5	0.199	0.199	0.199	0.199	0.199	0.199	0.199	0.199	0.199
100.0	0.199	0.199	0.199	0.199	0.299	0.199	0.199	0.199	0.199
102.5	0.299	0.299	0.299	0.299	0.398	0.299	0.299	0.299	0.299
105.0	0.498	0.498	0.498	0.498	0.498	0.498	0.498	0.498	0.498
107.5	0.597	0.597	0.597	0.597	0.697	0.597	0.597	0.597	0.597
110.0	0.896	0.796	1.095	0.896	0.896	0.896	1.095	0.796	0.896
112.5	1.194	1.095	3.682	1.194	1.294	1.194	3.682	1.095	1.194
115.0	1.592	4.975	11.642	5.373	1.692	5.373	11.642	4.975	1.592
117.5	11.144	19.701	23.681	20.000	10.348	20.000	23.681	19.701	11.144
120.0	29.950	37.014	37.213	38.407	30.149	38.407	37.213	37.014	29.950
122.5	49.153	53.233	51.740	55.720	51.044	55.720	51.740	53.233	49.153
125.0	68.854	69.750	66.964	73.232	71.740	73.232	66.964	69.750	68.854
127.5	90.147	86.963	82.784	91.341	93.829	91.341	82.784	86.963	90.147
130.0	111.938	105.868	99.600	110.744	116.813	110.744	99.600	105.868	111.938
132.5	134.126	126.863	118.803	132.236	140.594	132.236	118.803	126.863	134.126

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_.IES****CANDELA TABULATION - (Cont.)**

135.0	157.509	150.444	141.887	156.016	165.170	156.016	141.887	150.444	157.509
137.5	183.478	178.006	171.837	183.777	191.836	183.777	171.837	178.006	183.478
140.0	214.821	212.134	211.836	217.408	222.880	217.408	211.836	212.134	214.821
142.5	253.228	254.919	263.476	258.999	260.193	258.999	263.476	254.919	253.228
145.0	300.888	308.550	324.967	310.938	306.560	310.938	324.967	308.550	300.888
147.5	362.280	376.409	395.115	377.006	366.558	377.006	395.115	376.409	362.280
150.0	441.084	459.491	473.322	458.098	443.074	458.098	473.322	459.491	441.084
152.5	536.504	552.225	557.897	549.539	534.614	549.539	557.897	552.225	536.504
155.0	638.094	647.646	649.636	645.059	633.915	645.059	649.636	647.646	638.094
157.5	735.206	742.867	745.255	740.877	731.027	740.877	745.255	742.867	735.206
160.0	831.223	839.084	843.263	838.288	829.532	838.288	843.263	839.084	831.223
162.5	930.126	937.489	943.260	936.793	930.226	936.793	943.260	937.489	930.126
165.0	1028.830	1033.805	1040.770	1033.805	1027.835	1033.805	1040.770	1033.805	1028.830
167.5	1122.360	1125.345	1129.325	1124.350	1121.365	1124.350	1129.325	1125.345	1122.360
170.0	1206.935	1207.930	1206.935	1206.935	1205.940	1206.935	1206.935	1207.930	1206.935
172.5	1276.585	1276.585	1274.595	1274.595	1275.590	1274.595	1274.595	1276.585	1276.585
175.0	1330.315	1331.310	1329.320	1329.320	1330.315	1329.320	1329.320	1331.310	1330.315
177.5	1368.125	1368.125	1365.140	1366.135	1367.130	1366.135	1365.140	1368.125	1368.125
180.0	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000	1379.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	342.90	N.A.	17.00
0-30	589.36	N.A.	29.30
0-40	757.57	N.A.	37.70
0-60	907.57	N.A.	45.10
0-80	916.16	N.A.	45.50
0-90	916.28	N.A.	45.50
10-90	813.16	N.A.	40.40
20-40	414.67	N.A.	20.60
20-50	514.34	N.A.	25.60
40-70	158.17	N.A.	7.90
60-80	8.59	N.A.	0.40
70-80	0.43	N.A.	0.00
80-90	0.11	N.A.	0.00
90-110	0.66	N.A.	0.00
90-120	11.49	N.A.	0.60
90-130	74.28	N.A.	3.70
90-150	392.69	N.A.	19.50
90-180	1095.83	N.A.	54.50
110-180	1095.17	N.A.	54.40
0-180	2012.11	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	103.11
10-20	239.79
20-30	246.46
30-40	168.21
40-50	99.67
50-60	50.33
60-70	8.17
70-80	0.43
80-90	0.11
90-100	0.14
100-110	0.52
110-120	10.83
120-130	62.79
130-140	119.48
140-150	198.92
150-160	293.61
160-170	286.51
170-180	123.03

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	106	106	106	106	97	97	97	97	81	81	81	66	66	66	52	52	52	46
1	99	95	92	89	91	88	85	83	74	72	70	61	60	59	49	48	48	42
2	92	86	81	76	84	79	75	71	67	64	62	56	54	52	46	45	44	39
3	85	77	71	67	78	72	67	62	61	58	55	52	49	47	43	41	40	36
4	79	70	64	59	73	65	60	55	56	52	49	48	45	43	40	38	37	33
5	74	64	57	52	68	60	54	49	52	47	44	44	41	39	37	35	34	31
6	69	59	52	47	64	55	49	44	48	43	40	41	38	35	35	33	31	28
7	64	54	47	42	60	51	45	40	44	40	36	38	35	33	33	31	29	26
8	60	50	43	38	56	47	41	37	41	37	33	36	33	30	31	29	27	25
9	57	46	40	35	53	44	38	34	39	34	31	34	30	28	29	27	25	23
10	54	43	37	32	50	41	35	31	36	32	29	32	28	26	28	25	24	22

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

X=2H	Y=2H	13.7	14.4	14.8	15.4	16.8	14.0	14.7	15.1	15.7	17.1
	3H	13.5	14.1	14.6	15.2	16.5	13.9	14.5	14.9	15.5	16.8
	4H	13.4	14.0	14.5	15.0	16.4	13.8	14.3	14.8	15.3	16.7
	6H	13.3	13.8	14.4	14.9	16.3	13.6	14.2	14.7	15.2	16.6
	8H	13.3	13.8	14.3	14.8	16.2	13.6	14.1	14.6	15.1	16.5
	12H	13.2	13.7	14.3	14.7	16.1	13.5	14.0	14.6	15.0	16.4

UGR Viewed Endwise

4H	2H	13.5	14.1	14.6	15.1	16.5	13.8	14.4	14.9	15.4	16.8
	3H	13.3	13.8	14.4	14.8	16.2	13.6	14.1	14.7	15.1	16.5
	4H	13.2	13.6	14.3	14.7	16.1	13.5	13.9	14.6	15.0	16.4
	6H	13.1	13.5	14.2	14.5	15.9	13.4	13.8	14.5	14.8	16.2
	8H	13.0	13.4	14.1	14.4	15.8	13.3	13.7	14.4	14.7	16.2
	12H	13.0	13.3	14.0	14.3	15.8	13.3	13.6	14.4	14.6	16.1

8H	4H	13.0	13.4	14.1	14.4	15.8	13.3	13.7	14.4	14.7	16.2
	6H	12.9	13.2	14.0	14.3	15.7	13.2	13.5	14.3	14.6	16.0
	8H	12.9	13.1	14.0	14.2	15.6	13.2	13.4	14.3	14.5	15.9
	12H	12.8	13.0	13.9	14.1	15.6	13.1	13.3	14.2	14.4	15.9


12H	4H	13.0	13.3	14.0	14.3	15.8	13.3	13.6	14.4	14.6	16.1
	6H	12.8	13.1	13.9	14.2	15.6	13.1	13.4	14.2	14.5	15.9
	8H	12.8	13.0	13.9	14.1	15.6	13.1	13.3	14.2	14.4	15.9

Maximum UGR = 17.1

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4CSDI-L12-835U-L12-835D-XXX-DIM1-UNV-OM-CSU-ON-CSD-WM_.IES

POLAR GRAPH



Maximum Candela = 1379 Located At Horizontal Angle = 0, Vertical Angle = 180

1 - Vertical Plane Through Horizontal Angles (90 - 270)

2 - Horizontal Cone Through Vertical Angle (180) (Through Max. Cd.)