



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4DR-TL-P15-8TW-POE PR-OW-OF-CS-WET-CC_4000K.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20685.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 11-11-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 4"RND RECESSED LED DOWNLIGHT

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 4DR-TL-P15-8TW-POE PR-OW-OF-CS-WET-CC 4000K

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Classroom, Commercial, Corridor, Hotel, Industrial, Office, Downlight

[_SEARCH_MOUNTING] Recessed

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1114
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	91
Total Luminaire Watts	12.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.22
Spacing Criterion (Diagonal)	0.94
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.37 ft (Diameter)
Luminous Width (90-270)	0.37 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3378	3378	3378
55	1041	1041	1041
65	128	128	128
75	0	0	0
85	0	0	0

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4DR-TL-P15-8TW-POE PR-OW-OF-CS-WET-CC_4000K.IES

CANDELA TABULATION

	<u>0</u>
0	956.064
5	984.588
10	1014.168
15	1035.296
20	1081.251
25	1178.442
30	923.315
35	162.161
40	42.257
45	23.241
50	12.149
55	5.810
60	2.641
65	0.528
70	0.528
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 4DR-TL-P15-8TW-POE PR-OW-OF-CS-WET-CC_4000K.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	390.71	N.A.	35.10
0-30	893.69	N.A.	80.20
0-40	1087.64	N.A.	97.60
0-60	1112.77	N.A.	99.90
0-80	1113.95	N.A.	100.00
0-90	1113.95	N.A.	100.00
10-90	1019.25	N.A.	91.50
20-40	696.93	N.A.	62.60
20-50	716.21	N.A.	64.30
40-70	26.17	N.A.	2.30
60-80	1.18	N.A.	0.10
70-80	0.14	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1113.95	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	94.70
10-20	296.01
20-30	502.98
30-40	193.95
40-50	19.28
50-60	5.86
60-70	1.04
70-80	0.14
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4DR-TL-P15-8TW-POE PR-OW-OF-CS-WET-CC_4000K.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	106	111	109	107	105	105	103	102	101	100	98	98	97	96	94
2	108	104	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	86	83	82
4	98	91	85	81	96	90	85	81	87	83	80	85	82	79	84	81	78	77
5	93	85	79	75	92	84	79	75	82	78	74	81	77	74	79	76	73	72
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59
9	76	67	61	57	75	66	61	57	66	60	57	65	60	57	64	60	57	55
10	73	63	58	54	72	63	57	54	62	57	54	61	57	53	61	56	53	52

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 4DR-TL-P15-8TW-POE PR-OW-OF-CS-WET-CC_4000K.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	3H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	4H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	6H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	8H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	12H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4

UGR Viewed Endwise

4H	2H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	3H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	4H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	6H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	8H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	12H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
8H	4H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	6H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	8H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	12H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
12H	4H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	6H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	8H	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4

Maximum UGR = 0.4

POLAR GRAPH



Maximum Candela = 1178.442 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)