



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6CR-TL-L15-840-XXX-DIM-UNV-OW-CS-XX_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20685.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 26-JAN-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 1 BRIDGELUX V13 LED 6" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 6CR-TL-L15-840-xxx-DIM-UNV-OW-CS-xx

[LAMPCAT] V13 BXRE-40E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Classroom, Commercial, Corridor, Hotel, Industrial, Office, Downlight

[_SEARCH_MOUNTING] Surface

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1481
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	107
Total Luminaire Watts	13.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.22
Spacing Criterion (Diagonal)	0.94
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.37 ft (Diameter)
Luminous Width (90-270)	0.37 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4490	4490	4490
55	1384	1384	1384
65	171	171	171
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6CR-TL-L15-840-XXX-DIM-UNV-OW-CS-XX_.IES

CANDELA TABULATION

	<u>0</u>
0	1270.742
5	1308.653
10	1347.969
15	1376.052
20	1437.132
25	1566.312
30	1227.214
35	215.535
40	56.165
45	30.891
50	16.148
55	7.723
60	3.510
65	0.702
70	0.702
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 6CR-TL-L15-840-XXX-DIM-UNV-OW-CS-XX_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	519.30	N.A.	35.10
0-30	1187.83	N.A.	80.20
0-40	1445.62	N.A.	97.60
0-60	1479.03	N.A.	99.90
0-80	1480.59	N.A.	100.00
0-90	1480.59	N.A.	100.00
10-90	1354.72	N.A.	91.50
20-40	926.31	N.A.	62.60
20-50	951.94	N.A.	64.30
40-70	34.79	N.A.	2.30
60-80	1.56	N.A.	0.10
70-80	0.18	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1480.59	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	125.87
10-20	393.43
20-30	668.53
30-40	257.79
40-50	25.62
50-60	7.79
60-70	1.38
70-80	0.18
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6CR-TL-L15-840-XXX-DIM-UNV-OW-CS-XX_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94
2	108	104	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	86	83	82
4	98	91	85	81	96	90	85	81	87	83	80	85	82	79	84	81	78	77
5	93	85	79	75	92	84	79	75	82	78	74	81	77	74	79	76	73	72
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59
9	76	67	61	57	75	66	61	57	65	60	57	65	60	57	64	60	57	55
10	73	63	58	54	72	63	57	54	62	57	54	61	57	53	61	56	53	52


IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6CR-TL-L15-840-XXX-DIM-UNV-OW-CS-XX_.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	3H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	4H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	6H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	8H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	12H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
4H	2H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	3H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	4H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	6H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	8H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	12H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
8H	4H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	6H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	8H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	12H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
12H	4H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	6H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
	8H	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4

Maximum UGR = 1.4

POLAR GRAPH



Maximum Candela = 1566.312 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (90 - 270)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)