



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L10-835-DIM-UNV-OW-OF-CS-WET-CC\_.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
 [TEST]GEN FROM BALLABS TEST NO. 20687.0  
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC  
 [ISSUE DATE] 30-SEPT-2019  
 [MANUFAC] WILLIAMS INDOOR  
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO  
 [LUMINAIRE] 1 BRIDGELUX V13 LED 6"RND RECESSED CAST HOUSING DOWNLIGHT  
 [MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)  
 [LUMCAT] 6DR-TL-L10-835-DIM-UNV-OW-OF-CS-WET-CC  
 [LAMPCAT] V13 BXRE-35E2000  
 [ \_SEARCH\_SOURCETYPE] LED  
 [ \_SEARCH\_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight  
 [ \_SEARCH\_MOUNTING] Recessed

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	862
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	99
Total Luminaire Watts	8.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1597	1597	1597
55	556	556	556
65	116	116	116
75	0	0	0
85	0	0	0

IES INDOOR REPORT  
PHOTOMETRIC FILENAME : 6DR-TL-L10-835-DIM-UNV-OW-OF-CS-WET-CC\_.IES

CANDELA TABULATION

	<u>0</u>
0	687.626
5	649.379
10	714.769
15	713.535
20	745.202
25	815.116
30	800.722
35	248.401
40	34.135
45	18.918
50	11.104
55	5.346
60	2.879
65	0.823
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : 6DR-TL-L10-835-DIM-UNV-OW-OF-CS-WET-CC\_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	269.73	N.A.	31.30
0-30	637.86	N.A.	74.00
0-40	839.49	N.A.	97.40
0-60	860.86	N.A.	99.90
0-80	861.97	N.A.	100.00
0-90	861.97	N.A.	100.00
10-90	797.19	N.A.	92.50
20-40	569.76	N.A.	66.10
20-50	585.65	N.A.	67.90
40-70	22.48	N.A.	2.60
60-80	1.11	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	861.97	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	64.78
10-20	204.95
20-30	368.13
30-40	201.63
40-50	15.89
50-60	5.48
60-70	1.11
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT


PHOTOMETRIC FILENAME : 6DR-TL-L10-835-DIM-UNV-OW-OF-CS-WET-CC\_.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

POLAR GRAPH



Maximum Candela = 815.116 Located At Horizontal Angle = 0, Vertical Angle = 25  
# 1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)