


BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC.


1618 HEADLAND DR.
FENTON, MO 63026
(636) 343-6006
(636) 343-6051 FAX



BALLABS CERTIFIED TEST REPORT NO.: 20686.0 DATE 12/13/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: 1 BRIDGELUX V13 LED 6"RND RECESSED CAST HOUSING DOWNLIGHT
OPEN SEMI-SPEC SPUN ALUM REFL w/DOMED DIFF TOP LENS (WIDE)
ADVANCE #XI025C070V054DSM5 @ 470mA
CATALOG NBR: 6DR-TL-L20/835-DIM1-UNV-OW (V2B) -OF-CS-TD
LAMP TYPE : V13 BXRE-35E2000

CANDLEPOWER DISTRIBUTION

VERT ANG	AVERAGE CANDELA
0	970.
5	1003.
10	1075.
15	1108.
20	1118.
25	1089.
30	929.
35	566.
40	344.
45	214.
50	113.
55	19.
60	6.
65	3.
70	0.
75	0.
80	0.
85	0.
90	0.



Kelly J. Lee

NVLAP[®]
TESTING

NVLAP LAB CODE 200921-0

LUMEN SUMMARY

ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	914.	NA.	62.8	90-120	0.	NA.	.0
0- 40	1270.	NA.	87.3	90-130	0.	NA.	.0
0- 60	1452.	NA.	99.8	90-150	0.	NA.	.0
0- 90	1455.	NA.	100.0	90-180	0.	NA.	.0
TOTAL LUMINAIRE =				0-180	1455.	NA.	100.0

IES SPACING CRITERIA: ADJACENT= 1.3 DIAGONAL= .9

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

SIGNIFICANCE OF THE TEST IS LIMITED TO THE DEGREE THAT THE TESTED SAMPLE IS REPRESENTATIVE. OTHER FACTORS AFFECT FIELD PERFORMANCE.

BALLABS CERTIFIED TEST REPORT NO.: 20686.0 DATE 12/13/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: 1 BRIDGELUX V13 LED 6"RND RECESSED CAST HOUSING DOWNLIGHT
 OPEN SEMI-SPEC SPUN ALUM REFL w/DOMED DIFF TOP LENS(WIDE)
 ADVANCE #XI025C070V054DSM5 @ 470mA
 CATALOG NBR: 6DR-TL-L20/835-DIM1-UNV-OW(V2B)-OF-CS-TD
 LAMP TYPE : V13 BXRE-35E2000

LUMINANCES-CD/SQ-M
 HORIZONTAL ANGLE

VERT	0
ANGLE	
45	17906.
55	2002.
65	358.
75	0.
85	0.

MAXIMUM BRIGHTNESSES NOT MEASURED

ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80				.70				.50				.30				.10				.00
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00			
RCR																					
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00			
1	1.14	1.11	1.08	1.06	1.11	1.09	1.06	1.04	1.05	1.03	1.01	1.01	1.00	.98	.98	.96	.95	.94			
2	1.08	1.03	.99	.96	1.06	1.01	.98	.95	.98	.95	.93	.95	.93	.91	.93	.91	.89	.87			
3	1.02	.96	.91	.87	1.00	.95	.90	.86	.92	.88	.85	.90	.86	.84	.87	.85	.82	.81			
4	.97	.89	.84	.79	.95	.88	.83	.79	.86	.81	.78	.84	.80	.77	.82	.79	.76	.75			
5	.91	.83	.77	.72	.90	.82	.76	.72	.80	.75	.72	.78	.74	.71	.77	.73	.70	.69			
6	.87	.78	.71	.67	.85	.77	.71	.67	.75	.70	.66	.74	.69	.66	.72	.68	.65	.64			
7	.82	.72	.66	.62	.80	.71	.66	.61	.70	.65	.61	.69	.64	.61	.68	.64	.60	.59			
8	.77	.67	.60	.56	.75	.66	.60	.56	.65	.60	.56	.64	.59	.55	.63	.58	.55	.54			
9	.72	.61	.55	.51	.71	.61	.55	.51	.60	.54	.50	.59	.54	.50	.58	.53	.50	.49			
10	.67	.57	.50	.46	.66	.56	.50	.46	.55	.50	.46	.54	.49	.46	.54	.49	.46	.44			

TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20686.0 DATE 12/13/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: 1 BRIDGELUX V13 LED 6"RND RECESSED CAST HOUSING DOWNLIGHT
OPEN SEMI-SPEC SPUN ALUM REFL w/DOMED DIFF TOP LENS (WIDE)
ADVANCE #XI025C070V054DSM5 @ 470mA
CATALOG NBR: 6DR-TL-L20/835-DIM1-UNV-OW(V2B)-OF-CS-TD
LAMP TYPE : V13 BXRE-35E2000

ELECTRICAL CHARACTERISTICS 120.02V .1619A 18.9210W

LUMINOUS EFFICACY (LUMENS / WATTS) = 76.9

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08