



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DR-TL-L10-935-(L6)-DIM-UNV-OW-OF-CS_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST]GEN FROM BALLABS TEST NO. 20687.0
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
 [ISSUE DATE] 07-27-2020
 [MANUFAC] WILLIAMS INDOOR
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO 64836
 [LUMINAIRE] 1 BRIDGELUX V13 LED 6"RND RECESSED CAST HOUSING DOWNLIGHT
 [MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)
 [LUMCAT] 6DR-TL-L10-935-(L6)-DIM-UNV-OW-OF-CS
 [LAMPCAT] V13 BXRE-35E2000
 [_SEARCH_SOURCETYPE] LED
 [_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight
 [_SEARCH_MOUNTING] Recessed

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	502
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	100
Total Luminaire Watts	5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	930	930	930
55	324	324	324
65	68	68	68
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DR-TL-L10-935-(L6)-DIM-UNV-OW-OF-CS_.IES

CANDELA TABULATION

	<u>0</u>
0	400.450
5	378.177
10	416.258
15	415.539
20	433.981
25	474.697
30	466.314
35	144.660
40	19.879
45	11.017
50	6.467
55	3.114
60	1.677
65	0.479
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 6DR-TL-L10-935-(L6)-DIM-UNV-OW-OF-CS_.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	157.08	N.A.	31.30
0-30	371.47	N.A.	74.00
0-40	488.89	N.A.	97.40
0-60	501.34	N.A.	99.90
0-80	501.98	N.A.	100.00
0-90	501.98	N.A.	100.00
10-90	464.26	N.A.	92.50
20-40	331.81	N.A.	66.10
20-50	341.07	N.A.	67.90
40-70	13.09	N.A.	2.60
60-80	0.65	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	501.98	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY


Zone	Lumens
0-10	37.73
10-20	119.35
20-30	214.39
30-40	117.42
40-50	9.25
50-60	3.19
60-70	0.65
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 6DR-TL-L10-935-(L6)-DIM-UNV-OW-OF-CS_.IES****COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

POLAR GRAPH



Maximum Candela = 474.697 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)