


BALLABS CERTIFIED TEST REPORT NO.: 20349.0 DATE 04/24/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
WHITE MIXING CHAMBER & 6"CAST WHITE FLUSH TRIM w/SOLITE
LENS ADVANCE # XI025C070V054DSM1 @ 560mA
CATALOG NBR: 6DS-L20/835-DIM-UNV-L-W-OF-WH
LAMP TYPE : BXRE-35E2000

CANDLEPOWER DISTRIBUTION

VERT ANG	0	22.5	45	67.5	90	ZONAL LUMENS
0	1403.	1403.	1403.	1403.	1403.	
5	1407.	1400.	1400.	1399.	1402.	133.7
10	1394.	1388.	1387.	1382.	1390.	
15	1375.	1365.	1357.	1353.	1357.	385.6
20	1307.	1321.	1328.	1310.	1293.	
25	1145.	1177.	1263.	1189.	1150.	552.8
30	855.	955.	1078.	962.	856.	
35	524.	631.	845.	596.	526.	407.9
40	396.	435.	579.	418.	391.	
45	318.	337.	367.	328.	311.	260.7
50	255.	266.	274.	260.	255.	
55	201.	201.	206.	202.	199.	181.5
60	146.	147.	145.	145.	148.	
65	103.	103.	103.	102.	100.	101.3
70	68.	67.	63.	66.	67.	
75	40.	39.	39.	38.	38.	41.3
80	22.	20.	19.	19.	19.	
85	3.	4.	2.	3.	4.	3.7
90	0.	0.	0.	0.	0.	



NVLAP[®]
TESTING

NVLAP LAB CODE 200921-0

LUMEN SUMMARY

ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	1072.	NA.	51.8	90-120	0.	NA.	.0
0- 40	1480.	NA.	71.6	90-130	0.	NA.	.0
0- 60	1922.	NA.	92.9	90-150	0.	NA.	.0
0- 90	2068.	NA.	100.0	90-180	0.	NA.	.0
TOTAL LUMINAIRE = 0-180				2068.	NA.	100.0	

IES SPACING CRITERIA: END= 1.0 DIAGONAL = 1.2 CROSS= 1.0

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20349.0 DATE 04/24/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
 WHITE MIXING CHAMBER & 6"CAST WHITE FLUSH TRIM w/SOLITE
 LENS ADVANCE # XI025C070V054DSM1 @ 560mA
 CATALOG NBR: 6DS-L20/835-DIM-UNV-L-W-OF-WH
 LAMP TYPE : BXRE-35E2000

LUMINANCES-CD/SQ-M			
HORIZONTAL ANGLE			
VERT ANGLE	0	45	90
45	19198.	22167.	18803.
55	14965.	15372.	14803.
65	10376.	10376.	10155.
75	6669.	6489.	6309.
85	1606.	1071.	2141.

MAXIMUM BRIGHTNESSES NOT MEASURED

ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80		.70		.50		.30		.10		.00							
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00			
RCR																		
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1	1.12	1.09	1.06	1.04	1.10	1.07	1.04	1.02	1.03	1.01	.99	.99	.97	.96	.96	.94	.93	.91
2	1.06	1.00	.95	.91	1.03	.98	.94	.90	.95	.91	.88	.92	.89	.86	.89	.86	.84	.82
3	.99	.91	.86	.81	.97	.90	.85	.80	.87	.83	.79	.85	.81	.78	.82	.79	.76	.75
4	.93	.84	.77	.72	.91	.83	.76	.72	.80	.75	.71	.78	.74	.70	.76	.72	.69	.67
5	.87	.77	.70	.65	.85	.76	.69	.64	.74	.68	.64	.72	.67	.63	.70	.66	.62	.61
6	.81	.71	.64	.59	.80	.70	.63	.58	.68	.62	.58	.67	.62	.58	.65	.61	.57	.55
7	.76	.65	.58	.53	.75	.65	.58	.53	.63	.57	.53	.62	.56	.52	.61	.56	.52	.51
8	.71	.60	.53	.48	.70	.59	.53	.48	.58	.52	.48	.57	.52	.48	.56	.51	.47	.46
9	.66	.55	.48	.43	.65	.54	.48	.43	.53	.47	.43	.52	.47	.43	.51	.46	.43	.41
10	.62	.51	.44	.39	.61	.50	.44	.39	.49	.43	.39	.48	.43	.39	.48	.42	.39	.37

TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20349.0 DATE 04/24/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
WHITE MIXING CHAMBER & 6"CAST WHITE FLUSH TRIM w/SOLITE
LENS ADVANCE # XI025C070V054DSM1 @ 560mA
CATALOG NBR: 6DS-L20/835-DIM-UNV-L-W-OF-WH
LAMP TYPE : BXRE-35E2000

ELECTRICAL CHARACTERISTICS 120.02V .1892A 22.4580W

LUMINOUS EFFICACY (LUMENS / WATTS) = 92.1

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08

