


BALLABS CERTIFIED TEST REPORT NO.: 20359.0 DATE 04/25/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
WHITE MIXING CHAMBER & 6"CAST WHITE WALLWASH TRIM & SOLITE
LENS ADVANCE #XI025C070V054DSM1 @ 560mA
CATALOG NBR: 6DS-L20/835-DIM-UNV-L-WW-OF-WH
LAMP TYPE : BXRE-35E2000

0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER



Handwritten signature

NVLAP[®]
TESTING

NVLAP LAB CODE 200921-0

LUMEN SUMMARY							
ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	865.	NA.	54.9	90-120	0.	NA.	.0
0- 40	1128.	NA.	71.6	90-130	0.	NA.	.0
0- 60	1465.	NA.	93.1	90-150	0.	NA.	.0
0- 90	1574.	NA.	100.0	90-180	0.	NA.	.0
TOTAL LUMINAIRE =				0-180	1574.	NA.	100.0

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20359.0 DATE 04/25/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
 WHITE MIXING CHAMBER & 6"CAST WHITE WALLWASH TRIM & SOLITE
 LENS ADVANCE #XI025C070V054DSM1 @ 560mA
 CATALOG NBR: 6DS-L20/835-DIM-UNV-L-WW-OF-WH
 LAMP TYPE : BXRE-35E2000

CANDLEPOWER DISTRIBUTION
 0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER

VERT	HORIZONTAL									LUMENS		
	.0	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0	FRONT	BACK	TOTAL
0	1297.	1297.	1297.	1297.	1297.	1297.	1297.	1297.	1297.			
5	1309.	1304.	1298.	1297.	1294.	1295.	1291.	1287.	1294.	62.1	61.6	123.7
10	1276.	1270.	1276.	1280.	1278.	1279.	1270.	1256.	1258.			
15	1198.	1206.	1231.	1225.	1213.	1231.	1234.	1175.	1174.	172.3	170.5	342.8
20	1053.	1090.	1126.	1086.	1069.	1106.	1102.	1034.	1003.			
25	763.	844.	965.	847.	809.	900.	922.	850.	800.	195.6	202.5	398.1
30	534.	575.	706.	564.	536.	610.	722.	617.	550.			
35	431.	452.	473.	423.	402.	412.	513.	387.	331.	137.5	125.5	263.0
40	369.	382.	377.	354.	324.	305.	327.	253.	224.			
45	319.	323.	329.	293.	255.	229.	213.	174.	159.	119.1	78.1	197.2
50	282.	274.	279.	239.	198.	171.	146.	117.	110.			
55	239.	236.	219.	186.	146.	121.	96.	81.	72.	94.7	45.2	140.0
60	192.	188.	168.	140.	102.	81.	68.	55.	48.			
65	144.	142.	120.	94.	70.	53.	38.	29.	23.	58.6	20.4	78.9
70	103.	95.	79.	59.	39.	30.	17.	12.	14.			
75	64.	58.	43.	30.	19.	11.	3.	6.	8.	23.2	4.4	27.6
80	38.	30.	22.	14.	7.	3.	3.	3.	4.			
85	7.	7.	7.	3.	0.	0.	0.	0.	0.	2.7	.0	2.7
90	0.	0.	0.	0.	0.	0.	0.	0.	0.			

USE .500 FT. AS LENGTH AND .500 FT. AS WIDTH

BALLABS CERTIFIED TEST REPORT NO.: 20359.0 DATE 04/25/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
 WHITE MIXING CHAMBER & 6"CAST WHITE WALLWASH TRIM & SOLITE
 LENS ADVANCE #XI025C070V054DSM1 @ 560mA
 CATALOG NBR: 6DS-L20/835-DIM-UNV-L-WW-OF-WH
 LAMP TYPE : BXRE-35E2000

ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80				.70				.50				.30				.10				.00
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00
RCR																					
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00			
1	1.13	1.09	1.06	1.04	1.10	1.07	1.05	1.02	1.03	1.01	.99	.99	.98	.96	.96	.95	.93	.92			
2	1.06	1.00	.95	.91	1.03	.98	.94	.90	.95	.91	.88	.92	.89	.86	.89	.87	.85	.83			
3	1.00	.92	.86	.82	.97	.91	.85	.81	.88	.83	.80	.85	.82	.78	.83	.80	.77	.75			
4	.93	.85	.78	.73	.91	.83	.77	.73	.81	.76	.72	.79	.75	.71	.77	.73	.70	.68			
5	.87	.78	.71	.66	.86	.77	.70	.65	.75	.69	.65	.73	.68	.64	.71	.67	.64	.62			
6	.82	.72	.65	.60	.81	.71	.65	.60	.69	.64	.59	.68	.63	.59	.67	.62	.58	.57			
7	.77	.67	.60	.55	.76	.66	.59	.55	.64	.59	.54	.63	.58	.54	.62	.57	.54	.52			
8	.72	.61	.55	.50	.71	.61	.54	.50	.60	.54	.49	.58	.53	.49	.57	.53	.49	.47			
9	.68	.57	.50	.45	.66	.56	.50	.45	.55	.49	.45	.54	.49	.45	.53	.48	.45	.43			
10	.64	.52	.46	.41	.62	.52	.46	.41	.51	.45	.41	.50	.45	.41	.49	.44	.41	.39			



TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20359.0 DATE 04/25/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: GEN7 V13 LED 6"SHORT HEATSINK 6"SQ CAST HOUSING DOWNLIGHT
 WHITE MIXING CHAMBER & 6"CAST WHITE WALLWASH TRIM & SOLITE
 LENS ADVANCE #XI025C070V054DSM1 @ 560mA
 CATALOG NBR: 6DS-L20/835-DIM-UNV-L-WW-OF-WH
 LAMP TYPE : BXRE-35E2000

ELECTRICAL CHARACTERISTICS 120.09V .1891A 22.4540W

LUMINOUS EFFICACY (LUMENS / WATTS) = 70.1

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS
 UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08



Ø Degree Plane →