



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 6DS-L40-835-DIM-UNV-ON-OF-CS_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST]GEN FROM BALLABS TEST NO. 20364.0
 [TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
 [ISSUEDATE] 04-22-2022
 [MANUFAC] WILLIAMS INDOOR
 [OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO
 [LUMINAIRE] GEN7 V18 LED 6" TALL HEATSINK 6" SQ CAST HOUSING DOWNLIGHT
 [MORE] ACRYLIC NARROW TIR OPTIC & 6" SEMI-SPEC ALUMINUM TRIM
 [MORE] w/FROST FILM ADVANCE # XI036C070V054DSM1 @ 810mA
 [LUMCAT] 6DS-L40-835-DIM-UNV-O-N-OF-CS
 [LAMPCAT] BXRE-35E4000
 [_SEARCH_SOURCETYPE] LED
 [_SEARCH_APPLICATION] Indoor, Classroom, Commercial, Industrial, Office, Direct, Downlight
 [_SEARCH_MOUNTING] Recessed

CHARACTERISTICS

| | |
|---------------------------------|-----------------|
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Luminaire Lumens | 2855 |
| Total Luminaire Efficiency | N.A. |
| Luminaire Efficacy Rating (LER) | 68 |
| Total Luminaire Watts | 41.7 |
| Ballast Factor | 1.00 |
| CIE Type | Direct |
| Spacing Criterion (0-180) | 0.72 |
| Spacing Criterion (90-270) | 0.70 |
| Spacing Criterion (Diagonal) | 0.76 |
| Basic Luminous Shape | Rectangular |
| Luminous Length (0-180) | 0.50 ft |
| Luminous Width (90-270) | 0.50 ft |
| Luminous Height | 0.00 ft |

LUMINANCE DATA (cd/sq.m)

| Angle In Degrees | Average 0-Deg | Average 45-Deg | Average 90-Deg |
|---------------------|------------------|-------------------|-------------------|
| 45 | 9649 | 25862 | 10044 |
| 55 | 585 | 1658 | 585 |
| 65 | 0 | 0 | 0 |
| 75 | 0 | 0 | 0 |
| 85 | 0 | 0 | 0 |

IES INDOOR REPORT
 PHOTOMETRIC FILENAME : 6DS-L40-835-DIM-UNV-ON-OF-CS_.IES

CANDELA TABULATION

| | <u>0.0</u> | <u>22.5</u> | <u>45.0</u> | <u>67.5</u> | <u>90.0</u> |
|-----------|------------|-------------|-------------|-------------|-------------|
| 0 | 4214.895 | 4214.895 | 4214.895 | 4214.895 | 4214.895 |
| 5 | 4074.485 | 4057.584 | 4060.184 | 4038.083 | 4035.483 |
| 10 | 3609.053 | 3619.453 | 3629.854 | 3620.754 | 3570.050 |
| 15 | 3038.313 | 3021.412 | 3025.312 | 3030.512 | 3037.013 |
| 20 | 2425.970 | 2396.068 | 2360.965 | 2405.168 | 2393.468 |
| 25 | 1833.128 | 1804.526 | 1817.527 | 1817.527 | 1794.126 |
| 30 | 1320.892 | 1274.089 | 1333.893 | 1280.590 | 1272.789 |
| 35 | 819.057 | 874.961 | 975.068 | 861.960 | 835.959 |
| 40 | 461.532 | 533.037 | 691.648 | 522.637 | 423.830 |
| 45 | 158.611 | 244.417 | 425.130 | 249.617 | 165.112 |
| 50 | 40.303 | 59.804 | 152.111 | 62.404 | 35.102 |
| 55 | 7.801 | 11.701 | 22.102 | 11.701 | 7.801 |
| 60 | 1.300 | 2.600 | 3.900 | 1.300 | 0.000 |
| 65 | 0.000 | 1.300 | 0.000 | 0.000 | 0.000 |
| 70 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 75 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 80 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 85 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 90 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DS-L40-835-DIM-UNV-ON-OF-CS_.IES

ZONAL LUMEN SUMMARY

| Zone | Lumens | %Lamp | %Fixt |
|---------|---------|-------|--------|
| 0-20 | 1214.05 | N.A. | 42.50 |
| 0-30 | 2048.74 | N.A. | 71.80 |
| 0-40 | 2608.92 | N.A. | 91.40 |
| 0-60 | 2854.14 | N.A. | 100.00 |
| 0-80 | 2854.81 | N.A. | 100.00 |
| 0-90 | 2854.81 | N.A. | 100.00 |
| 10-90 | 2481.68 | N.A. | 86.90 |
| 20-40 | 1394.87 | N.A. | 48.90 |
| 20-50 | 1616.66 | N.A. | 56.60 |
| 40-70 | 245.89 | N.A. | 8.60 |
| 60-80 | 0.67 | N.A. | 0.00 |
| 70-80 | 0.00 | N.A. | 0.00 |
| 80-90 | 0.00 | N.A. | 0.00 |
| 90-110 | 0.00 | N.A. | 0.00 |
| 90-120 | 0.00 | N.A. | 0.00 |
| 90-130 | 0.00 | N.A. | 0.00 |
| 90-150 | 0.00 | N.A. | 0.00 |
| 90-180 | 0.00 | N.A. | 0.00 |
| 110-180 | 0.00 | N.A. | 0.00 |
| 0-180 | 2854.81 | N.A. | 100.00 |

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

| Zone | Lumens |
|---------|--------|
| 0-10 | 373.13 |
| 10-20 | 840.92 |
| 20-30 | 834.69 |
| 30-40 | 560.18 |
| 40-50 | 221.79 |
| 50-60 | 23.43 |
| 60-70 | 0.67 |
| 70-80 | 0.00 |
| 80-90 | 0.00 |
| 90-100 | 0.00 |
| 100-110 | 0.00 |
| 110-120 | 0.00 |
| 120-130 | 0.00 |
| 130-140 | 0.00 |
| 140-150 | 0.00 |
| 150-160 | 0.00 |
| 160-170 | 0.00 |
| 170-180 | 0.00 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DS-L40-835-DIM-UNV-ON-OF-CS_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

| RC | 80 | | | | 70 | | | | 50 | | | 30 | | | 10 | | | 0 |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |
| 1 | 114 | 111 | 109 | 106 | 111 | 109 | 107 | 105 | 105 | 103 | 101 | 101 | 100 | 98 | 98 | 97 | 96 | 94 |
| 2 | 108 | 103 | 100 | 96 | 106 | 102 | 98 | 95 | 99 | 96 | 93 | 96 | 93 | 91 | 93 | 91 | 89 | 88 |
| 3 | 103 | 97 | 92 | 88 | 101 | 95 | 91 | 87 | 93 | 89 | 86 | 90 | 87 | 85 | 88 | 85 | 83 | 82 |
| 4 | 98 | 91 | 85 | 81 | 96 | 89 | 84 | 81 | 87 | 83 | 80 | 85 | 82 | 79 | 83 | 80 | 78 | 76 |
| 5 | 93 | 85 | 79 | 75 | 91 | 84 | 79 | 75 | 82 | 78 | 74 | 81 | 77 | 73 | 79 | 76 | 73 | 71 |
| 6 | 89 | 80 | 74 | 70 | 87 | 79 | 74 | 70 | 78 | 73 | 69 | 76 | 72 | 69 | 75 | 71 | 68 | 67 |
| 7 | 84 | 75 | 69 | 65 | 83 | 75 | 69 | 65 | 73 | 68 | 65 | 72 | 68 | 64 | 71 | 67 | 64 | 63 |
| 8 | 80 | 71 | 65 | 61 | 79 | 71 | 65 | 61 | 69 | 64 | 61 | 68 | 64 | 61 | 68 | 63 | 60 | 59 |
| 9 | 77 | 67 | 62 | 58 | 76 | 67 | 61 | 58 | 66 | 61 | 57 | 65 | 60 | 57 | 64 | 60 | 57 | 56 |
| 10 | 73 | 64 | 58 | 54 | 72 | 63 | 58 | 54 | 63 | 58 | 54 | 62 | 57 | 54 | 61 | 57 | 54 | 53 |


IES INDOOR REPORT
PHOTOMETRIC FILENAME : 6DS-L40-835-DIM-UNV-ON-OF-CS_.IES

UGR TABLE - CORRECTED

| | | | | | | | | | | | |
|----------------|------|----------------------|-----|-----|-----|-----|--------------------|-----|-----|-----|-----|
| Reflectances | | | | | | | | | | | |
| Ceiling Cavity | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 | |
| Walls | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 | |
| Floor Cavity | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | |
| Room Size | | UGR Viewed Crosswise | | | | | UGR Viewed Endwise | | | | |
| X=2H | Y=2H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 3H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 4H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 6H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 8H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 12H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| 4H | 2H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 3H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 4H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 6H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 8H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 12H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| 8H | 4H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 6H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 8H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 12H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| 12H | 4H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 6H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |
| | 8H | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 | 3.6 |

Maximum UGR = 3.6

POLAR GRAPH



Maximum Candela = 4214.895 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)