



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L10-835-XXX-DIM-UNV-OW-SG-XX_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 4-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO

[LUMINAIRE] 1 BRIDGELUX V13 LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[LUMCAT] 8CR-TL-L10-835-xxx-DIM-UNV-OW-SG-xx

[LAMPCAT] V13 BXRE-35E2000

[_SEARCH_SOURCETYPE] LED

[_SEARCH_APPLICATION] Indoor, Architectural, Classroom, Commercial, Healthcare, Office, Downlight

[_SEARCH_MOUNTING] Surface

CHARACTERISTICS

| | |
|---------------------------------|--------------------|
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Luminaire Lumens | 933 |
| Total Luminaire Efficiency | N.A. |
| Luminaire Efficacy Rating (LER) | 107 |
| Total Luminaire Watts | 8.7 |
| Ballast Factor | 1.00 |
| CIE Type | Direct |
| Spacing Criterion (0-180) | 1.26 |
| Spacing Criterion (90-270) | 1.26 |
| Spacing Criterion (Diagonal) | 0.98 |
| Basic Luminous Shape | Circular |
| Luminous Length (0-180) | 0.48 ft (Diameter) |
| Luminous Width (90-270) | 0.48 ft (Diameter) |
| Luminous Height | 0.00 ft |

LUMINANCE DATA (cd/sq.m)

| Angle In Degrees | Average 0-Deg | Average 45-Deg | Average 90-Deg |
|------------------|---------------|----------------|----------------|
| 45 | 1728 | 1728 | 1728 |
| 55 | 602 | 602 | 602 |
| 65 | 126 | 126 | 126 |
| 75 | 0 | 0 | 0 |
| 85 | 0 | 0 | 0 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8CR-TL-L10-835-XXX-DIM-UNV-OW-SG-XX_.IES

CANDELA TABULATION

| | |
|----|----------|
| | <u>0</u> |
| 0 | 744.263 |
| 5 | 702.866 |
| 10 | 773.642 |
| 15 | 772.307 |
| 20 | 806.582 |
| 25 | 882.255 |
| 30 | 866.675 |
| 35 | 268.861 |
| 40 | 36.946 |
| 45 | 20.476 |
| 50 | 12.019 |
| 55 | 5.787 |
| 60 | 3.116 |
| 65 | 0.890 |
| 70 | 0.000 |
| 75 | 0.000 |
| 80 | 0.000 |
| 85 | 0.000 |
| 90 | 0.000 |

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8CR-TL-L10-835-XXX-DIM-UNV-OW-SG-XX_.IES****ZONAL LUMEN SUMMARY**

| Zone | Lumens | %Lamp | %Fixt |
|---------|--------|-------|--------|
| 0-20 | 291.95 | N.A. | 31.30 |
| 0-30 | 690.40 | N.A. | 74.00 |
| 0-40 | 908.64 | N.A. | 97.40 |
| 0-60 | 931.77 | N.A. | 99.90 |
| 0-80 | 932.97 | N.A. | 100.00 |
| 0-90 | 932.97 | N.A. | 100.00 |
| 10-90 | 862.85 | N.A. | 92.50 |
| 20-40 | 616.69 | N.A. | 66.10 |
| 20-50 | 633.89 | N.A. | 67.90 |
| 40-70 | 24.33 | N.A. | 2.60 |
| 60-80 | 1.20 | N.A. | 0.10 |
| 70-80 | 0.00 | N.A. | 0.00 |
| 80-90 | 0.00 | N.A. | 0.00 |
| 90-110 | 0.00 | N.A. | 0.00 |
| 90-120 | 0.00 | N.A. | 0.00 |
| 90-130 | 0.00 | N.A. | 0.00 |
| 90-150 | 0.00 | N.A. | 0.00 |
| 90-180 | 0.00 | N.A. | 0.00 |
| 110-180 | 0.00 | N.A. | 0.00 |
| 0-180 | 932.97 | N.A. | 100.00 |

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

| Zone | Lumens |
|---------|--------|
| 0-10 | 70.12 |
| 10-20 | 221.83 |
| 20-30 | 398.46 |
| 30-40 | 218.24 |
| 40-50 | 17.20 |
| 50-60 | 5.93 |
| 60-70 | 1.20 |
| 70-80 | 0.00 |
| 80-90 | 0.00 |
| 90-100 | 0.00 |
| 100-110 | 0.00 |
| 110-120 | 0.00 |
| 120-130 | 0.00 |
| 130-140 | 0.00 |
| 140-150 | 0.00 |
| 150-160 | 0.00 |
| 160-170 | 0.00 |
| 170-180 | 0.00 |

IES INDOOR REPORT


PHOTOMETRIC FILENAME : 8CR-TL-L10-835-XXX-DIM-UNV-OW-SG-XX_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

| RC | 80 | | | | 70 | | | | 50 | | | 30 | | | 10 | | | 0 |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |
| 1 | 114 | 111 | 108 | 106 | 111 | 109 | 106 | 104 | 105 | 103 | 101 | 101 | 99 | 98 | 97 | 96 | 95 | 94 |
| 2 | 108 | 103 | 99 | 96 | 106 | 101 | 98 | 95 | 98 | 95 | 93 | 95 | 93 | 91 | 92 | 90 | 89 | 87 |
| 3 | 102 | 96 | 91 | 87 | 100 | 95 | 90 | 86 | 92 | 88 | 85 | 90 | 86 | 84 | 87 | 85 | 82 | 81 |
| 4 | 97 | 90 | 84 | 80 | 95 | 89 | 83 | 79 | 86 | 82 | 79 | 84 | 81 | 78 | 83 | 79 | 77 | 75 |
| 5 | 92 | 84 | 78 | 74 | 91 | 83 | 77 | 73 | 81 | 76 | 73 | 79 | 75 | 72 | 78 | 74 | 71 | 70 |
| 6 | 87 | 78 | 72 | 68 | 86 | 78 | 72 | 68 | 76 | 71 | 67 | 75 | 70 | 67 | 73 | 70 | 67 | 65 |
| 7 | 83 | 74 | 68 | 63 | 82 | 73 | 67 | 63 | 72 | 67 | 63 | 70 | 66 | 62 | 69 | 65 | 62 | 61 |
| 8 | 79 | 69 | 63 | 59 | 78 | 69 | 63 | 59 | 67 | 62 | 59 | 66 | 62 | 58 | 65 | 61 | 58 | 57 |
| 9 | 75 | 65 | 59 | 55 | 74 | 65 | 59 | 55 | 64 | 58 | 55 | 63 | 58 | 55 | 62 | 57 | 54 | 53 |
| 10 | 71 | 61 | 55 | 51 | 70 | 61 | 55 | 51 | 60 | 55 | 51 | 59 | 54 | 51 | 58 | 54 | 51 | 50 |

POLAR GRAPH



Maximum Candela = 882.255 Located At Horizontal Angle = 0, Vertical Angle = 25
1 - Vertical Plane Through Horizontal Angles (90 - 270)
2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)