



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8DR-L40-930-EM10W-OW-CS-DIM-UNV_(EMER MODE).IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST]

[TESTLAB]

[ISSUE DATE] 10-04-2022

[MANUFAC] H.E. WILLIAMS

[LUMCAT] 8DR-L40-930-EM10W-OW-CS-DIM-UNV

[LUMINAIRE] 8.5 INCH RECESSED LED DOWNLIGHT FIXTURE WITH

[MORE] SEMI-SPECULAR TRIM, (1) LED MODULE AND (1) ELECTRONIC DRIVER

[LAMPCAT] X1-3000K LED

[LAMP] (1) 3000K LED MODULE

[BALLASTCAT]

[BALLAST]

[OTHER]

[MOUNTING] RECESSED

[ABSOLUTE] TEST ABSOLUTE PHOTOMETRY IS BASED ON CALIBRATION FACTORS

[MORE] CREATED USING A 1000 WATT, NIST TRACEABLE, OMNIDIRECTIONAL

[MORE] LAB LUMEN STANDARD IN THE GONIOPHOTOMETER WITH A TEST

[MORE] DISTANCE OF 28 FEET

[ABSOLUTENOTE] DATA SHOWN IS ABSOLUTE FOR THE SAMPLE PROVIDED.

[ABSOLUTE LUMENS] 10287

[CONVERT] Photometric web converted from original test data

[CONVERT] Photometric web converted from original test data

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	680
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	68
Total Luminaire Watts	10
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.06
Spacing Criterion (90-270)	1.06
Spacing Criterion (Diagonal)	0.96
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.71 ft (Diameter)
Luminous Width (90-270)	0.71 ft (Diameter)
Luminous Height	0.00 ft

IES INDOOR REPORT
PHOTOMETRIC FILENAME : 8DR-L40-930-EM10W-OW-CS-DIM-UNV_(EMER MODE).IES

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1572	1572	1572
55	261	261	261
65	179	179	179
75	139	139	139
85	104	104	104

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8DR-L40-930-EM10W-OW-CS-DIM-UNV_(EMER MODE).IES****CANDELA TABULATION**

	<u>0</u>
0.0	664.863
2.5	665.723
5.0	669.028
7.5	656.269
10.0	643.510
12.5	635.312
15.0	609.926
17.5	587.251
20.0	568.872
22.5	550.361
25.0	527.554
27.5	487.491
30.0	416.358
32.5	338.547
35.0	260.604
37.5	187.486
40.0	123.030
42.5	74.836
45.0	40.723
47.5	17.850
50.0	8.793
52.5	6.875
55.0	5.487
57.5	4.562
60.0	3.834
62.5	3.239
65.0	2.777
67.5	2.314
70.0	1.917
72.5	1.587
75.0	1.322
77.5	1.058
80.0	0.793
82.5	0.529
85.0	0.331
87.5	0.132
90.0	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8DR-L40-930-EM10W-OW-CS-DIM-UNV_(EMER MODE).IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	234.44	N.A.	34.50
0-30	470.67	N.A.	69.20
0-40	632.93	N.A.	93.10
0-60	675.48	N.A.	99.30
0-80	679.66	N.A.	99.90
0-90	680.03	N.A.	100.00
10-90	617.21	N.A.	90.80
20-40	398.49	N.A.	58.60
20-50	435.87	N.A.	64.10
40-70	45.32	N.A.	6.70
60-80	4.17	N.A.	0.60
70-80	1.40	N.A.	0.20
80-90	0.38	N.A.	0.10
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	680.03	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	62.82
10-20	171.62
20-30	236.23
30-40	162.26
40-50	37.38
50-60	5.17
60-70	2.77
70-80	1.40
80-90	0.38
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8DR-L40-930-EM10W-OW-CS-DIM-UNV_(EMER MODE).IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	111	108	106	111	108	106	104	104	103	101	101	99	98	97	96	95	93
2	108	103	99	95	105	101	97	94	98	95	92	95	92	90	92	90	88	87
3	102	96	91	87	100	94	90	86	92	88	84	89	86	83	87	84	82	80
4	97	89	84	79	95	88	83	79	86	81	78	84	80	77	82	79	76	74
5	92	83	77	73	90	82	77	73	81	76	72	79	75	71	77	74	71	69
6	87	78	72	68	86	77	71	67	76	71	67	74	70	66	73	69	66	64
7	83	73	67	63	81	72	67	63	71	66	62	70	65	62	69	65	62	60
8	78	69	63	58	77	68	62	58	67	62	58	66	61	58	65	61	58	56
9	75	65	59	55	73	64	58	54	63	58	54	62	58	54	61	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	49

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8DR-L40-930-EM10W-OW-CS-DIM-UNV_(EMER MODE).IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	3H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	4H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	6H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	8H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	12H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

UGR Viewed Endwise

4H	2H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	3H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	4H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	6H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	8H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	12H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8H	4H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	6H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	8H	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1
	12H	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.3
12H	4H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	6H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	8H	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.2

Maximum UGR = 0.3

POLAR GRAPH



Maximum Candela = 669.028 Located At Horizontal Angle = 0, Vertical Angle = 5
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (5) (Through Max. Cd.)