



IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-827-0-D-DIM-UNV_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] GEN FROM BALLABS TEST NO. 19927.0
[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
[ISSUEDATE] 2023-07-14
[MANUFAC] WILLIAMS INDOOR
[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO 64836
[LUMINAIRE] CONTINUOUS COVE LUMINAIRE @ 0 DEGREE
[MORE] WITH FROSTED ACRYLIC LENS
[LUMCAT] CX-3-08-L4-827-0-D-DIM-UNV
[LAMPCAT] 22 INCH LED ARRAYS
[_SEARCH_SOURCETYPE] LED
[_SEARCH_APPLICATION] INDOOR, CLASSROOM, EDUCATIONAL, ATRIUM
[_SEARCH_MOUNTING] COVE

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1469
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	119
Total Luminaire Watts	12.3
Ballast Factor	1.00
CIE Type	Indirect
Spacing Criterion (0-180)	N.A.
Spacing Criterion (90-270)	N.A.
Spacing Criterion (Diagonal)	N.A.
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.22 ft
Luminous Width (90-270)	3.69 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	0	0	0
55	0	0	0
65	0	0	0
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-827-0-D-DIM-UNV_.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>	<u>112.5</u>	<u>135.0</u>	<u>157.5</u>	<u>180.0</u>
0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
35	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
40	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
45	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
50	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
55	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
60	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
65	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
70	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
75	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
80	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
85	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
90	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
95	0.758	1.137	4.170	24.263	28.434	29.192	26.538	26.538	27.296
100	19.335	28.813	40.944	61.796	70.515	65.587	61.037	61.796	64.070
105	77.718	87.575	89.850	102.361	110.322	111.459	104.635	103.498	104.635
110	131.173	130.415	133.827	143.305	145.201	158.469	150.887	147.096	143.684
115	165.673	169.843	175.150	178.563	182.354	201.688	190.694	187.661	185.766
120	205.100	208.892	215.716	219.128	224.056	241.495	232.018	231.259	225.952
125	244.149	249.836	253.248	261.209	266.896	275.236	274.099	272.583	265.380
130	282.440	294.192	293.055	301.774	306.324	314.285	314.664	313.906	304.049
135	316.560	332.104	328.692	339.686	345.373	354.471	349.922	353.713	343.098
140	351.059	364.707	365.466	373.427	379.872	391.245	386.317	384.421	379.872
145	382.147	392.383	396.932	402.998	410.580	422.333	417.783	411.717	413.613
150	410.580	423.849	426.124	431.431	439.772	455.695	448.112	438.634	445.838
155	441.667	453.420	454.557	457.211	467.447	482.233	474.650	464.035	470.480
160	465.931	478.441	476.167	477.683	488.677	501.188	495.122	482.991	487.161
165	482.612	498.914	497.018	495.122	504.979	515.215	509.150	497.018	499.293
170	493.606	508.770	508.770	507.633	516.732	524.693	518.627	503.084	504.979
175	495.122	513.699	516.353	515.595	524.693	531.138	523.935	503.842	504.600
180	514.836	514.836	514.836	514.836	514.836	514.836	514.836	514.836	514.836

IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-827-0-D-DIM-UNV_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	0.00	N.A.	0.00
0-30	0.00	N.A.	0.00
0-40	0.00	N.A.	0.00
0-60	0.00	N.A.	0.00
0-80	0.00	N.A.	0.00
0-90	0.00	N.A.	0.00
10-90	0.00	N.A.	0.00
20-40	0.00	N.A.	0.00
20-50	0.00	N.A.	0.00
40-70	0.00	N.A.	0.00
60-80	0.00	N.A.	0.00
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	130.07	N.A.	8.90
90-120	311.38	N.A.	21.20
90-130	547.32	N.A.	37.30
90-150	1065.52	N.A.	72.50
90-180	1469.23	N.A.	100.00
110-180	1339.16	N.A.	91.10
0-180	1469.23	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	0.00
10-20	0.00
20-30	0.00
30-40	0.00
40-50	0.00
50-60	0.00
60-70	0.00
70-80	0.00
80-90	0.00
90-100	25.20
100-110	104.87
110-120	181.31
120-130	235.94
130-140	263.42
140-150	254.77
150-160	213.38
160-170	141.26
170-180	49.07


IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-827-0-D-DIM-UNV_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	95	95	95	95	81	81	81	81	56	56	56	32	32	32	10	10	10	0
1	87	83	79	76	74	71	68	65	48	47	45	28	27	26	9	9	8	0
2	79	72	66	62	67	62	57	53	42	40	37	24	23	22	8	7	7	0
3	72	63	56	51	61	54	49	44	37	34	31	21	20	18	7	6	6	0
4	65	56	48	43	56	48	42	37	33	29	26	19	17	16	6	6	5	0
5	60	49	42	36	51	42	36	32	29	25	22	17	15	13	5	5	4	0
6	55	44	36	31	47	38	32	27	26	22	19	15	13	11	5	4	4	0
7	50	39	32	27	43	34	28	23	23	19	17	14	11	10	4	4	3	0
8	47	35	28	23	40	30	24	20	21	17	14	12	10	9	4	3	3	0
9	43	32	25	20	37	28	22	18	19	15	13	11	9	8	4	3	3	0
10	40	29	22	18	34	25	19	16	17	14	11	10	8	7	3	3	2	0

POLAR GRAPH



Maximum Candela = 531.138 Located At Horizontal Angle = 112.5, Vertical Angle = 175
1 - Vertical Plane Through Horizontal Angles (112.5 - 292.5) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (175) (Through Max. Cd.)