



IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-840-0-D-DIM-UNV_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] GEN FROM BALLABS TEST NO. 19927.0
[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
[ISSUEDATE] 2023-07-14
[MANUFAC] WILLIAMS INDOOR
[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO 64836
[LUMINAIRE] CONTINUOUS COVE LUMINAIRE @ 0 DEGREE
[MORE] WITH FROSTED ACRYLIC LENS
[LUMCAT] CX-3-08-L4-840-0-D-DIM-UNV
[LAMPCAT] 22 INCH LED ARRAYS
[_SEARCH_SOURCETYPE] LED
[_SEARCH_APPLICATION] INDOOR, CLASSROOM, EDUCATIONAL, ATRIUM
[_SEARCH_MOUNTING] COVE

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1560
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	127
Total Luminaire Watts	12.3
Ballast Factor	1.00
CIE Type	Indirect
Spacing Criterion (0-180)	N.A.
Spacing Criterion (90-270)	N.A.
Spacing Criterion (Diagonal)	N.A.
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.22 ft
Luminous Width (90-270)	3.69 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	0	0	0
55	0	0	0
65	0	0	0
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-840-0-D-DIM-UNV_.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>	<u>112.5</u>	<u>135.0</u>	<u>157.5</u>	<u>180.0</u>
0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
35	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
40	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
45	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
50	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
55	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
60	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
65	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
70	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
75	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
80	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
85	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
90	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
95	0.805	1.208	4.428	25.764	30.192	30.997	28.179	28.179	28.985
100	20.531	30.595	43.477	65.618	74.877	69.644	64.813	65.618	68.033
105	82.526	92.992	95.408	108.692	117.146	118.354	111.108	109.900	111.108
110	139.287	138.482	142.105	152.169	154.182	168.272	160.220	156.195	152.572
115	175.920	180.349	185.985	189.608	193.633	214.164	202.490	199.269	197.256
120	217.787	221.813	229.059	232.682	237.915	256.433	246.369	245.564	239.928
125	259.251	265.290	268.913	277.367	283.405	292.261	291.054	289.443	281.795
130	299.910	312.390	311.182	320.441	325.272	333.725	334.128	333.323	322.856
135	336.141	352.646	349.023	360.697	366.736	376.397	371.566	375.592	364.320
140	372.774	387.266	388.072	396.525	403.369	415.446	410.213	408.200	403.369
145	405.784	416.654	421.484	427.925	435.977	448.456	443.625	437.184	439.197
150	435.977	450.066	452.482	458.118	466.974	483.882	475.831	465.766	473.415
155	468.987	481.466	482.674	485.492	496.361	512.061	504.010	492.738	499.582
160	494.751	508.036	505.620	507.231	518.905	532.189	525.748	512.866	517.295
165	512.464	529.774	527.761	525.748	536.215	547.084	540.643	527.761	530.177
170	524.138	540.241	540.241	539.033	548.695	557.148	550.707	534.202	536.215
175	525.748	545.474	548.292	547.487	557.148	563.992	556.343	535.007	535.813
180	546.682	546.682	546.682	546.682	546.682	546.682	546.682	546.682	546.682

IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-840-0-D-DIM-UNV_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	0.00	N.A.	0.00
0-30	0.00	N.A.	0.00
0-40	0.00	N.A.	0.00
0-60	0.00	N.A.	0.00
0-80	0.00	N.A.	0.00
0-90	0.00	N.A.	0.00
10-90	0.00	N.A.	0.00
20-40	0.00	N.A.	0.00
20-50	0.00	N.A.	0.00
40-70	0.00	N.A.	0.00
60-80	0.00	N.A.	0.00
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	138.12	N.A.	8.90
90-120	330.64	N.A.	21.20
90-130	581.18	N.A.	37.30
90-150	1131.43	N.A.	72.50
90-180	1560.11	N.A.	100.00
110-180	1421.99	N.A.	91.10
0-180	1560.11	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	0.00
10-20	0.00
20-30	0.00
30-40	0.00
40-50	0.00
50-60	0.00
60-70	0.00
70-80	0.00
80-90	0.00
90-100	26.76
100-110	111.36
110-120	192.52
120-130	250.54
130-140	279.72
140-150	270.53
150-160	226.58
160-170	150.00
170-180	52.10


IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L4-840-0-D-DIM-UNV_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	95	95	95	95	81	81	81	81	56	56	56	32	32	32	10	10	10	0
1	87	83	79	76	74	71	68	65	48	47	45	28	27	26	9	9	8	0
2	79	72	66	62	67	62	57	53	42	40	37	24	23	22	8	7	7	0
3	72	63	56	51	61	54	49	44	37	34	31	21	20	18	7	6	6	0
4	65	56	48	43	56	48	42	37	33	29	26	19	17	16	6	6	5	0
5	60	49	42	36	51	42	36	32	29	25	22	17	15	13	5	5	4	0
6	55	44	36	31	47	38	32	27	26	22	19	15	13	11	5	4	4	0
7	50	39	32	27	43	34	28	23	23	19	17	14	11	10	4	4	3	0
8	47	35	28	23	40	30	24	20	21	17	14	12	10	9	4	3	3	0
9	43	32	25	20	37	28	22	18	19	15	13	11	9	8	4	3	3	0
10	40	29	22	18	34	25	19	16	17	14	11	10	8	7	3	3	2	0

POLAR GRAPH



Maximum Candela = 563.992 Located At Horizontal Angle = 112.5, Vertical Angle = 175
1 - Vertical Plane Through Horizontal Angles (112.5 - 292.5) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (175) (Through Max. Cd.)