



IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L6-840-0-D-DIM-UNV_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] GEN FROM BALLABS TEST NO. 19927.0
[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
[ISSUEDATE] 2023-07-14
[MANUFAC] WILLIAMS INDOOR
[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO 64836
[LUMINAIRE] CONTINUOUS COVE LUMINAIRE @ 0 DEGREE
[MORE] WITH FROSTED ACRYLIC LENS
[LUMCAT] CX-3-08-L6-840-0-D-DIM-UNV
[LAMPCAT] 22 INCH LED ARRAYS
[_SEARCH_SOURCETYPE] LED
[_SEARCH_APPLICATION] INDOOR, CLASSROOM, EDUCATIONAL, ATRIUM
[_SEARCH_MOUNTING] COVE

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2321
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	129
Total Luminaire Watts	18.04
Ballast Factor	1.00
CIE Type	Indirect
Spacing Criterion (0-180)	N.A.
Spacing Criterion (90-270)	N.A.
Spacing Criterion (Diagonal)	N.A.
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.22 ft
Luminous Width (90-270)	3.69 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	0	0	0
55	0	0	0
65	0	0	0
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L6-840-0-D-DIM-UNV_.IES

CANDELA TABULATION

	<u>0.0</u>	<u>22.5</u>	<u>45.0</u>	<u>67.5</u>	<u>90.0</u>	<u>112.5</u>	<u>135.0</u>	<u>157.5</u>	<u>180.0</u>
0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
35	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
40	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
45	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
50	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
55	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
60	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
65	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
70	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
75	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
80	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
85	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
90	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
95	1.198	1.796	6.587	38.324	44.911	46.108	41.917	41.917	43.114
100	30.539	45.509	64.671	97.606	111.378	103.594	96.408	97.606	101.199
105	122.756	138.325	141.918	161.678	174.253	176.050	165.271	163.475	165.271
110	207.188	205.990	211.380	226.350	229.344	250.302	238.326	232.338	226.949
115	261.679	268.266	276.650	282.039	288.027	318.566	301.201	296.410	293.416
120	323.956	329.944	340.722	346.112	353.896	381.441	366.471	365.273	356.890
125	385.633	394.615	400.004	412.579	421.561	434.735	432.939	430.544	419.166
130	446.113	464.676	462.879	476.652	483.838	496.413	497.011	495.814	480.245
135	500.005	524.557	519.167	536.533	545.515	559.886	552.701	558.689	541.922
140	554.497	576.054	577.252	589.827	600.006	617.971	610.186	607.192	600.006
145	603.599	619.767	626.953	636.534	648.510	667.073	659.887	650.306	653.300
150	648.510	669.468	673.061	681.444	694.618	719.768	707.792	692.822	704.199
155	697.612	716.175	717.972	722.163	738.331	761.685	749.709	732.942	743.122
160	735.936	755.697	752.104	754.499	771.865	791.625	782.044	762.882	769.469
165	762.284	788.032	785.038	782.044	797.613	813.781	804.200	785.038	788.631
170	779.649	803.601	803.601	801.805	816.176	828.751	819.170	794.619	797.613
175	782.044	811.386	815.578	814.380	828.751	838.931	827.554	795.817	797.015
180	813.182	813.182	813.182	813.182	813.182	813.182	813.182	813.182	813.182

IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L6-840-0-D-DIM-UNV_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	0.00	N.A.	0.00
0-30	0.00	N.A.	0.00
0-40	0.00	N.A.	0.00
0-60	0.00	N.A.	0.00
0-80	0.00	N.A.	0.00
0-90	0.00	N.A.	0.00
10-90	0.00	N.A.	0.00
20-40	0.00	N.A.	0.00
20-50	0.00	N.A.	0.00
40-70	0.00	N.A.	0.00
60-80	0.00	N.A.	0.00
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	205.45	N.A.	8.90
90-120	491.83	N.A.	21.20
90-130	864.50	N.A.	37.30
90-150	1682.99	N.A.	72.50
90-180	2320.64	N.A.	100.00
110-180	2115.19	N.A.	91.10
0-180	2320.64	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	0.00
10-20	0.00
20-30	0.00
30-40	0.00
40-50	0.00
50-60	0.00
60-70	0.00
70-80	0.00
80-90	0.00
90-100	39.81
100-110	165.65
110-120	286.38
120-130	372.67
130-140	416.08
140-150	402.41
150-160	337.03
160-170	223.12
170-180	77.50


IES INDOOR REPORT
PHOTOMETRIC FILENAME : CX-3-08-L6-840-0-D-DIM-UNV_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	95	95	95	95	81	81	81	81	56	56	56	32	32	32	10	10	10	0
1	87	83	79	76	74	71	68	65	48	47	45	28	27	26	9	9	8	0
2	79	72	66	62	67	62	57	53	42	40	37	24	23	22	8	7	7	0
3	72	63	56	51	61	54	49	44	37	34	31	21	20	18	7	6	6	0
4	65	56	48	43	56	48	42	37	33	29	26	19	17	16	6	6	5	0
5	60	49	42	36	51	42	36	32	29	25	22	17	15	13	5	5	4	0
6	55	44	36	31	47	38	32	27	26	22	19	15	13	11	5	4	4	0
7	50	39	32	27	43	34	28	23	23	19	17	14	11	10	4	4	3	0
8	47	35	28	23	40	30	24	20	21	17	14	12	10	9	4	3	3	0
9	43	32	25	20	37	27	22	18	19	15	13	11	9	8	4	3	3	0
10	40	29	22	18	34	25	19	16	17	14	11	10	8	7	3	3	2	0

POLAR GRAPH



Maximum Candela = 838.931 Located At Horizontal Angle = 112.5, Vertical Angle = 175
1 - Vertical Plane Through Horizontal Angles (112.5 - 292.5) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (175) (Through Max. Cd.)